

- (6) Velan(閥在功能測試時所遭遇之問題)
- (7) Flowserve(閥、幫浦與驅動器在功能測試時所遭遇之問題)
- (8) Limitorque(驅動器在功能測試時所遭遇之問題)
- (9) Rotork(驅動器在功能測試時所遭遇之問題)
- (10) Weir Group(閥、幫浦與驅動器在功能測試時所遭遇之問題)
- (11) Valcor(龍門電廠電磁閥洩漏議題)

4. KEI 參訪期間

公差的第二個禮拜，我前往位於德州 Sugar Land 的 Kalsi Engineering Inc 進行參訪。參訪期間感謝 Ryan Sicking 先生之陪伴解說。參訪共進行兩天，

第一天我先進行簡報(附件)表明我參訪之目的，並與 KEI 之專家們針對我所提出之議題進行討論，以吸收彼等之經驗並進行經驗交換。

簡報內容主要包括以下議題：

- (1) 三偏心蝶閥(以龍門電廠電動閥 1P26-MBV-1001C2 為例)需求扭力分析結果，與動態測試實際測試數值差異比較
- (2) 龍門電廠 HPCF 管路震動議題討論
- (3) 以 KVAP 軟體進行需求推力分析時 Load Sensitivity Behavior 數值選用邏輯討論
- (4) 電動閥動態測試時分組(Grouping)原則討論
- (5) 閘閥離座力評估討論
- (6) 電動閥最弱環應力分析遵循 OBE(Operation-Basis Evaluation)或 SSE(Safety Shutdown Evaluation)之基礎討論。

第二天進行動態流場實驗室參觀與新版 KVAP 軟體功能展示。

三、心得

此次國外公差，除結識各國核電工業主管電動閥與氣動閥之官員、專家與業者，增長了我的知識/技術，也同時拓展了爾後的人脈與知識之網絡。若能持續發展現有之知識與人脈的網絡，確信對我國核電動力閥(電動閥與氣動閥)技術之發展有重大的幫助。以下是我在此次公差後之心得。

國內在電動閥相關法規之管制作為，依舊停留在早期，約 20 年前僅以 GL 89-10 & GL 96-05 法規為主之管制(對原能會而言)/維護(對台電而言)觀念中，相對地在管制作為與維護觀念上都仍是原地踏步。對於目前法規都已放寬或都已允許採用其他方式進行評估/維護/採購之方式，國內都未能聯接上世界的脈動。尤其沒能對於採用風險評估技術(Risk Assessment)對安全相關電動閥進行相關之管制作為，或未能真正落實法規原則並結合系統概念以對電動閥進行動態測試前之有效分組(Grouping)，或未能引用運轉&維護(O&M)法規改善維護程序，或未能對現役電動閥驅動器馬達老化導致驅動功能衰退之議題提出對應措施等。這些都是美國 NRC 目前正進行的管制趨勢，細觀這些議題之內容，確實對電廠運轉之安全性與電廠維護成本之降低能有直接之助益。

在氣動閥之議題方面，舉凡依循美國法規進行管制之核電廠，會要求所有安全有關氣動閥之管制作為，皆依循 RIS 2000-03 之要求，即對所有安全有關氣動閥，不論在運轉前或運轉後，皆須依循 GL 89-10 之要求，仿電動閥管制之模式，擬定氣動閥計畫(AOV Program)以進行安全有關氣動閥之技術資訊管制、功能評估、靜&動態測試、測試數據管理與趨勢分析(Trending)與改善評估等作為。此外在 GL 89-10 所要求之工作項目完成後，亦須依法規 GL 96-05 之要求，對氣動閥依其功能餘裕(Margin)進行分類以執行定期營運中(In-Service)測試。對此依我之了解，似乎國內在此一範圍之管制作為仍有不足。建議原能會可參考前述之法規要求，進行必要的管制以維護核能安全。

在參訪廠商的心得方面，很感慨因國外市場規模大，相關之技術服務非常多樣化與細緻化，核電廠若有需求可自行整合相關之技術服務商，或委託顧問商進行技術整合以解決電廠之問題。國內因市場規模小，無法建立如國外般的技術供應鏈。因此在問題發生時往往無法

由整合國內技術供應商而獲得解決，而需透過代理人向國外尋求技術整合。如此不得已之作法，不僅耗時耗事且國內在技術上與觀念上皆不如國外廠商，因此品質無法完全掌握。

管制單位在技術方面不夠純熟，因此很容易陷入硬梆梆的依法規管制卻無法變通之情況，尤其在興建中的電廠此情況格外嚴重。此一情況很容易造成管制者與被管制者間因溝通無共識而產生之怨懟。

四、建 議 事 項

建議事項如下：

- (一) 不論管制單位(原能會)、運轉單位(核電廠)或研究單位(核研所)都能持續派員前往參加類似研討會，多建立技術與人脈之網絡。不論在管制或維護方面，日後必定能獲得數倍的回報。
- (二) 各核電廠之閥類數量眾多、種類亦多樣化；然國內在閥類專業方面之專業人才卻異常缺乏，建議能補充人員以免辛苦建立的技術因後繼無人而逐漸流失。
- (三) 依法規要求，強化氣動閥之管制作為，以確保氣動閥之正常功能。
- (四) 核電廠應將電動閥或氣動閥的所有工作，自維護保養計畫之撰擬、功能評估、測試或測試後之功能預測等，皆歸單一專屬單位負責。目前之權責單位多達三、四個，往往造成權責難以釐清，彼此互相推託之情況。

五、照片剪輯



圖 1：MOVUG & AOVUG 研討會地點
Hyatt Regency Riverfront Hotel
Jacksonville, Florida, USA



圖 2：研討會註冊櫃台



圖 3：研討會會場入口



圖 4：研討會演講廳



圖 5：NRC MOV 之主管官員
Mr. Michael Farnan



圖 6：Kalsi Engineering 之攤位



圖 7：參訪驅動器生產商 Rotork
與技術經理 Ivan Burnell 合影



圖 8：Rotork 驅動器剖面



圖 9：參訪電磁閥生產商 Valcor 公司
與品保經理 Steven Gatcomb 合影




圖 10：Valcor 電磁閥剖面



圖 11：參訪測試設備生產商 Teledyne Brown
Test Inc.試用 Quiklook III 測試主機



圖 12：參訪測試設備生產商 Crane Nuclear
與測試工程師 Matthew Gulyas 合影



圖 13：參訪 Score Atlanta 公司攤位
與 Stan Hale 訪談



圖 14：參訪 Global Valve Services 攤位
與 Eric Chapman 訪談



圖 15：與 Enercon 公司工程師 John Summers
& Chiluwa Mdala 討論管路振動問題後合影



圖 16：伴手禮(臺華窯瓷器&鳳梨酥)



圖 17：Kalsi 公司之動態迴路試驗場



圖 18：流場測試中之電動閥模組



圖 19：氣動閥摩擦力試驗機台



圖 20：動態流場模擬試驗機台



圖 21：動態流場模擬試驗機台之測試夾具



圖 22：Kalsi 公司產品使用者國家之國旗



圖 23：高壓實驗管路與夾具



圖 24：與 KEI 公司高級幹部合影
左起：Ryan Sicking, Daniel Averitt, 我,
Dr. Kalsi, Dr. Bhira

六、附 錄

(一) MOVUG 會議資訊

(二) AOVUG 會議資訊

(三) 參訪 KEI 之簡報

Agenda

Motor-Operated Valve Users' Group Annual Meeting

January 13 – 15, 2014

Hyatt Regency Riverfront Hotel

Jacksonville, Florida, USA

Sunday, January 12, 2014

3:00 - 7:00 PM Early Registration Registration Desk

7:00 - 9:00 PM Steering Committee Meeting
(Committee Members Only)**Monday, January 13, 2014**

7:00 - 8:30 AM Continental Breakfast (Conference or Exhibitor Badge required) Exhibit Hall foyer

7:00 - 4:30 PM Registration desk open Registration Desk

MUG Committee Meetings**Grand Ballroom 1/2/3**8:00 - 9:30 AM Limitorque Technical Advisory Group (TAG)
(Open to Utility Members and Vendors that support Limitorque actuators) John Arnold, Chairman**9:30 AM– 10:00 AM Morning Break (Expo opens. Expo hours 9:30-6:30) Exhibit Hall**

10:00 – 11:30 AM Closed Discussion Forum (Utility Members Only) Facilitator

11:30 AM – 1:00 PM Hosted Lunch & Networking Break (included with Registration fee) **Exhibit Hall****MUG General Session # 1****Grand Ballroom 1/2/3**1:00 – 1:10 PM Opening Remarks and Roll Call Gary Foster - FirstEnergy Corp.
MOV Users' Group Chairman

1:10 – 1:30 PM BWROG Update Ted Neckowicz - BWROG VTRG Chairman

1:30 – 1:50 PM PWROG Update Chad Smith – PWROG Chairman

1:50 – 2:10 PM EPRI Update Nick Camilli – EPRI

2:10 – 2:30 PM ASME OM Appendix III Implementation Ed Cavey – True North Consulting

2:30 - 3:00 PM Afternoon Break Exhibit Hall

3:00 – 3:40PM MOV Trace Evaluation Walter Darmetko – Crane Nuclear

3:40 – 4:00 PM Part 1: Salem JOG Class D Testing Dan Maxey - Salem & Hope Creek - PSEG
Ludwig Haber & David Schowalter – Alden4:00 – 4:30 PM Part 2: Salem JOG Class D Testing Data Analysis Dan Maxey - Salem & Hope Creek - PSEG
Jeff Gratz - MPR**4:30 - 6:30 PM Welcome Reception Exhibit Hall****6:30 - 10:00 PM Hospitality Events Check Signs**

Tuesday, January 14, 2014

7:00 - 4:30 AM	Registration desk open	Registration Desk
7:00 - 8:30 AM	Continental Breakfast (Conference or Exhibitor Badge required)	Exhibit Hall foyer

MUG General Session # 2**Grand Ballroom 1/2/3**

8:00 – 8:30 AM	Status of Regulatory Activity on Motor Operated Valves	Michael Farnan – NRC
8:30 – 8:40 AM	NRC Question/Answer Session	Michael Farnan – NRC
8:40 – 9:00 AM	Responding to a Valve 10 CFR Part 21 Report Flowserve – Anchor/Darling Double Disc Gate Valve	Ted Neckowicz – Exelon Floyd Bensinger - Flowserve
9:00 – 9:20 AM	Update on MOV Evaluations for NFPA805 - Lessons Learned	Paul Knittle - MPR
9:20 – 9:40 AM	International JOG MOV Program Implementation Experience	Ike Ezekoye, Jennifer Meneely, Bill Turkowski, – Westinghouse

9:40 AM – 10:10 AM Morning Break (Expo opens. Expo hours 9:40-6:30) Exhibit Hall

10:10 – 10:30 AM	In-situ Seat Replacement as an alternative to Valve Replacement	Dave Hart – Babcock & Wilcox
10:30 – 10:50 AM	Weir Parallel Slide Gate Valve application in HPCI at Hope Creek Generating Station	Don Johnson – PSEG Chris Gilbert - NEPCO
10:50 – 11:10 AM	Thermal Binding in Wedge Gate Valves- New Insights	David Phillips – OPG Darlington Nuclear Bahir Eldiwany – Kalsi Engineering
11:10 – 11:30 AM	As-Found Condition of a Henry Pratt Model 1100 Butterfly Valve	Roger Van Steenberg – Millstone

11:30 AM – 1:00 PM Hosted Lunch & Networking Break (included with Registration fee) Exhibit Hall**MUG General Session # 3****Grand Ballroom 1/2/3**

1:00 – 1:20 PM	Follow-up to the 2012 MOV Hot Short Lessons Learn Presentation	Dave McKibbin – DP Engineering
1:20 – 1:40 PM	Comparison of MOV Stroke Times of DC Motors with Actual Valve Tests	Ike Ezekoye, Bill Turkowski, Terrence Matty Preston Vock – Westinghouse
1:40 – 2:10 PM	Motor Operated Valve Uncertainties	Ron Kropp – Palo Verde, APS
2:10 – 2:30 PM	New Business/Voting	Gary Foster – MUG Chairman

2:30 PM – 3:00 PM Afternoon Break Exhibit Hall

3:00 – 3:20PM	Prevention of valve damage from high torque or high speed valve actuators	Ivan Burnell – Rotork
3:20 – 3:40 PM	Stem Nut Wear Tests	Ken Brown – Eco Fluid Center Ltd
3:40 – 4:00 PM	Experiences of 10 years Operation of Online Valve Monitoring Systems with Measurements in the Motor Control Center	Karlheinz Hein – AREVA
4:00 – 4:20 PM	Non-Program MOV PM Optimization	Ken Hart – AP Services/Curtiss Wright

4:30 - 6:30 PM Vendor Displays/Reception Exhibit Hall**6:30 - 10:00 PM Hospitality Events Check Signs**

Wednesday, January 15, 2014

7:00 - 8:30 AM Continental Breakfast (Conference or Exhibitor Badge required) Exhibit Hall foyer

MUG Users Group & Limitorque Training Meetings River Terrace, 3rd Floor
Users Group Track - River Terrace 1 (3rd Floor)

8:00 – 8:30 AM	Kalsi Engineering Update	M.S. Kalsi, Kalsi Engineering
8:30 – 9:00 AM	AREVA Update	Vedat Ataman, AREVA
9:00 – 9:30 AM	Teledyne Update	Mike Richard, Teledyne
9:30 – 10:00 AM	Crane Update	Buddy Jolley, Crane

Training Track - River Terrace 2 (3rd Floor)

8:00 – 10:00 AM	Maintenance of Anchor Darling Double Disk Gate Valves	John Arnold
-----------------	---	-------------

10:00 - 10:45 AM Morning Break Exhibit Hall

MUG Final Reports Grand Ballroom 1/2/3

10:45 – 11:10 AM	TAG Committee Report	John Arnold
11:10 – 11:45 AM	Limitorque Update	Kyle Ramsey – Limitorque
11:45 – 12:00 PM	Closing Comments	Gary Foster - FirstEnergy Corp. MOV Users' Group Chairman

12:00 PM MUG Adjourn

12:00 – 1:00 PM Co - Hosted Lunch & Networking Break (included with Registration fee) **Exhibit Hall**

Thank you for joining us this year. Please make plans to attend our next Motor-Operated Valve Users Group (MUG) Conference in January 2015 in Jacksonville, Florida:

2015 Motor-Operated Valve Users Group (MUG) Conference

January 12th – 14th, 2015

Hyatt Regency Riverfront Hotel

Jacksonville, Florida, USA

www.movusersgroup.com

Agenda

Air-Operated Valve Users' Group Annual Meeting

**January 15 - 17, 2014
Hyatt Regency
Jacksonville, Florida USA**

Monday, January 13, 2014

7:00 AM – 4:30 PM AUG/CANUG/FLMUG Conference Early Registration

Registration Desk

Tuesday, January 14, 2014

7:00 AM – 4:30 PM AUG/CANUG/FLMUG Conference Early Registration

Registration Desk

Wednesday, January 15, 20147:00 AM – 4:30 PM **Registration Desk Open** Registration Desk7:00 – 8:30 AM **Continental Breakfast (Conference or Exhibitor Badge Required)** Exhibit Hall foyer**AUG General Session #1****Grand Ballroom 1/2/3**8:00 – 8:15 AM **Opening Remarks/Introductions**8:15 – 8:45 AM **Insights from AOV Assessments & Benchmarking** *Tim Scoggins, Ameren Missouri*8:45 – 9:15 AM **Impact of measurement uncertainties in AOV Testing** *Ron Kropp, APS/
Tom Brunson, TDSS*9:15 – 9:45 AM **Effective Diaphragm Area Test Program Update** *Kevin Cortis, Dominion/
Mark Barracough Wolf Creek/
Zach Leutwyler, Kalsi*
- Masoneilan Model 38 Size 18 Diaphragm Actuator9:45 – 10:15 AM **Morning Break (Expo opens. Expo hours 9:30 - 6:00)** Exhibit Hall**AUG General Session #2 - Workshops****See locations below**10:15 – 11:30 AM **Main Steam Isolation Valve Workshop** *Marie Murphy, Exelon/ Dmitri Moundous,
Progress Energy*
• MSIV Diagnostic Testing - Steve Gallogly
• Service Modifications to MSIVs in the Field - Don Bowers, WEIR10:15 – 11:30 AM **Mandatory Appendix IV/ EDA Analytical Impacts** *Fred Setzer, Duke Energy*10:15 – 11:30 AM **Maintenance Workshop** *Tim Prestifilippo, SNC*
• Effects of Packing Adjustments on Seat Load/Leakage /Using Midas Meter – Bobby Greenlees, Score
• Update and Demonstration of Electronic Packages and Apps – Nick Camilli, EPRI11:30 AM – 1:00 PM **Hosted Lunch & Networking Break** *(Included with registration fee.)* Exhibit Hall11:30 – 1:00 PM **New AUG Attendees Orientation & Lunch** *Chuck Linden, APS* TBD1:00 – 2:00 PM **Closed Session (Utility Only) – OE Discussion** *JR Price, STP***AOV Users Groups---Diagnostics, Calculation Software, & Other**NOTE: Users Group Meetings are repeated 2:00-2:55 and 3:00-4:002:05 PM – 3:00 PM & **Crane Users Group** *(Crane)* TBD
3:05 PM – 4:00 PM2:05 PM – 3:00 PM & **FlowScanner Users Group** *(Fisher)* TBD
3:05 PM – 4:00 PM2:05 PM – 3:00 PM & **UltraCheck-A Users Group** *(Areva/Framatome)* TBD
3:05 PM – 4:00 PM2:05 PM – 3:00 PM & **KVAP Users Group** *(Kalsi Engineering)* TBD
3:05 PM – 4:00 PM2:05 PM – 3:00 PM & **Teledyne Users Group** *(Teledyne)* TBD
3:05 PM – 4:00 PM4:00 – 6:00 PM **Welcome Reception & Vendor Exhibit Displays** Exhibit Hall6:00 – 10:00 PM **Hospitality Events** Check Signs

Thursday, January 16, 2014

7:00 AM – 4:30 PM	Registration Desk Open	Registration Desk
-------------------	-------------------------------	--------------------------

7:00 – 8:30 AM	Continental Breakfast (Conference or Exhibitor Badge Required)	Exhibit Hall foyer
----------------	---	---------------------------

AUG General Session #3 - TRAINING**See Locations below**

8:00 – 8:30 AM	NRC Presentation with Q&A	<i>Jason Carneal, U.S. NRC</i>
8:30 – 9:00 AM	EPRI PPM	<i>Paul Knittle & Jeff Gratz, MPR / Nick Camilli, EPRI</i>
9:00 – 9:30 AM	Morning Break (Expo opens. Expo hours 9:00 - 6:30)	Exhibit Hall
9:30 – 10:30 AM	Masoneilan Workshop	<i>Fred Setzer, Duke / Jim Meeker, Curtiss Wright</i>
9:30 – 10:30 AM	Strain Gage Use and Interpretation of Traces	<i>Marie Murphy, Exelon</i>
	- AREVA..... Room TBD	- Fisher.... Room TBD
	- Crane..... Room TBD	- Teledyne.... Room TBD
9:30 – 10:30 AM	CCI Workshop	<i>Chuck Linden, APS / Kurt Christianson, IMI Nuclear</i>
10:30 – 11:30 AM	Repeat the above 3	
11:30 AM – 1:00 PM	Hosted Lunch & Networking Break	<i>(Included with registration fee.)</i> Exhibit Hall

AUG General Session #4**Grand Ballroom 1/2/3**

1:00 – 1:30 PM	Pressure Boundary Materials, 17-4 Stem Material Failures	<i>Gabriel Ilevbare/Nick Camilli, EPRI</i>
1:30 – 2:00 PM	Destructive Testing Results of 17-4 Stems Exposed to Temperatures Above 500F	<i>Andy Wilkens Sizewell/EDF Energy</i>
2:00 – 2:30 PM	Afternoon Break	Exhibit Hall
2:30 – 3:15 PM	Diaphragm Behavior of Masoneilan 18HPI Actuator	<i>Christophe Merieux, EDF</i>
3:15 – 3:30 PM	Steering Committee Elections	
3:30 – 4:00 AM	OE Related to Heater Drain Valve Issues	<i>Dmitri Moundous, Progress Energy/ Fred Setzer, Duke Energy</i>
4:00 – 4:30 PM	Q-Turn Air Actuator Testing and Efficiency Study	<i>Fred Setzer, Duke Energy/ Zach Leutwyler, Kalsi</i>
4:30 – 6:30 PM	Reception & Vendor Exhibit Displays	Exhibit Hall
4:30 – 5:00 PM	Vendor Quality Subcommittee (Closed Session- Utility only -after the General Session)	<i>Fred Setzer, Duke Energy</i> Salon E
6:30 – 10:00 PM	Hospitality Events	Check Signs

Friday, January 17, 2014

7:00 AM – Noon	Registration Desk Open (Note: Expo is closed today.)	Registration Desk
7:00 – 8:30 AM	Continental Breakfast (Conference Required)	Exhibit Hall foyer
AUG General Session #5		
8:00 – 8:30 AM	Evaluation of Modifications Impacts on AOV Stroke Times	<i>Paul Knittle, MPR</i>
8:30 – 9:00 AM	Predictive Modeling of Safety-Related Air Operated Valves (AOVs) for Nuclear Power Plants	<i>Manuel Villena Rivera, Iberdrola</i>
9:00 – 9:30 AM	Materials Failure Analysis	<i>Thomas Wait, Power Labs/Exelon</i>
9:30 – 10:00 AM	Morning Break (No expo today.)	Exhibit Hall foyer
10:00 – 10:30 AM	Process Based on Nuclear Protocols Implemented at Coal Fired Fossil Plant	<i>Alan Trojan, Duke Energy</i>
10:30 – 11:00 AM	Risk assessment & reliability of AOVs with degraded air purity AUG Outage	<i>Antoine Raybaud, EDF</i>
11:00 – 11:30 AM	AUG Outage Survey Results	<i>Marie Murphy, Exelon</i>
11:30 AM	Conference Adjourns	

Thank you for joining us this year. Please make plans to attend our next Air-Operated Valve Users Group (AUG) Conference in January 2015 in Jacksonville, Florida:

Air-Operated Valve Users Group (AUG) Conference
January 14 - 16, 2015
The Hyatt Regency Jacksonville Riverfront Hotel
Jacksonville, Florida, USA
www.aovusersgroup.com

KEI Visit

中華民國103年元月二十日

KVAP Issues

- Main concerns in OM Code App III & IV
- DP test results, extrapolated to blow down conditions ? >> **Act. Disqualified, owner unhappy?** e.g. High Flow MOVs

Extrapolation methodology >> all happy, tricky?

Lungmen Concerns

1. 1P26-MBV-1001C1, C2,C3 are sister MOVs, w/ design pressure 150 psi, double eccentric BV, 14", 14NA-IW5, TQ tripped MOV
2. While 1P26-MBV-1001C2 DP tested, under DP 50 psi, @ C1 opened & C3 closed, C2 TQ tripped before disc seated, MOV stopped by LS tripped.>> considered C2 unable to overcome DP, to test C1 under same flow conditions.

1001C1 Trace #	TQ , O	Max Tq, O	TQ, C	Max. Tq, C14	Remarks
S5	4.5	676.8	4.75	1220.6	50 psi, LS trips
S9	4.5		3	421.5	50 psi, TQ trips on-off, LS failed to close
S10	4.5	611.5	3.5	450.0	50 psi, by LS trips

Flow should assist 'Closing', but C14 cannot close @ 567.8(predicted) @ 50psi Piping configuration/flow disturbance/choked flow resulted in?

Lungmen Concerns

- HPCF Piping vibration, exceeds regulation value
- Natural freq of piping/pumping pulse induced vibration/flow disturbance/piping design



Others

■ LSB value: **by bounding value/ by tested value?**

LSB varies much in MOVs in same train

w/ same value, MOVs disqualified

■ Grouping methodology: factor priority?


(valve manufacturer, model and size; valve flow, temperature, pressure, hydraulics, and installation configuration; valve materials and condition; seat/guide stresses; and performance)

Different priority arrangement >> DP MOVs varies

LM MOVs, by XXX v/v maker, undersized, w/o amb. temp, voltage drop considerations, TQ set @ max.

Others(con.)




- Unwedge force: big to be in danger for stem



Tolerance
above
predicted ?

(KS #1
EK-HV144,
broken disc
ears)

End of Cycle	O9 Th	O9 Tq
11 (1996)	16,232	186.4
14 (2000)	27,286	401.9
20 (2009)	39,966	546.4



Others

Weakest Link Evaluation, upon
SSE/ OBE ? Regulation?

Thanks !